

**FIRE INSPECTION APPLICATION
RENTAL PROPERTIES**

PROPERTY ADDRESS _____

BLOCK _____ LOT _____

PHONE _____ # OF APARTMENTS _____

LOCAL CONTACT _____ PHONE # _____

OWNERS NAME _____

MAILING ADDRESS _____

CITY _____ STATE _____ ZIP _____

PHONE # _____

E-MAIL ADDRESS _____

REQUIREMENTS PRIOR TO INSPECTION

ONE 2A:10BC (MINIMUM) RATED FIRE EXTINGUISHER FOR EACH KITCHEN. IT MUST BE HUNG AND TAGGED FOR CURRENT YEAR.

ONE SMOKE DETECTOR ON EVERY LEVEL AND IN EACH SLEEPING ROOM.

ONE CARBON MONOXIDE (CO) DETECTOR IF THERE ARE FUEL BURNING APPLIANCES (I.E. natural or LP gas heat, cooking, oil heat, fireplaces, etc.) THIS ALSO APPLIES IF THERE IS AN ATTACHED GARAGE.

NO OPEN ELECTRICAL JUNCTION BOXES OR PERMANENT USE OF EXTENSION CORDS.

GFCI RECEPTACLES WITHIN 6' OF SINKS, TUBS, SHOWERS, ETC.

ALL BARRIERS TO FIRE MUST BE INTACT. (SHEET ROCK, DOORS, ETC)

NO STORAGE WITHIN 3' OF HEATER, 30" OF ELECTRICAL BOXES.

NO B-B-Q GRILLS ON DECKS OR UNDER OVERHANGS.

GAS SHUT-OFFS FOR ALL GAS APPLIANCES.